

Town of Waterford  
Board of Selectmen and Utility Commission  
Harrisons' Landing Sewers and Roadway Improvements  
And  
Maple Court Water & Sewer Extension  
Bid #12-102

**RESPONSE TO QUESTIONS**  
**November 14, 2011**

Question: Borings on plans are labeled b-1 thru b-36 but boring logs are labeled p-1 thru p-36. Are these the correct boring logs or a typographical error?

Response: The boring labels are a typographical error (p- vs. b-); the boring numbers will correspond between the plan set and the boring logs.

Question: Item #31 part 1 utility construction unit price bid form, installation of 1 1/4" low pressure force main services, is listed as quantity 350 and unit of each. Please clarify if unit or quantity are correct or unit should be lf(linear feet).

Response: The unit is linear feet (LF). This is addressed in Addendum #2, which is posted on the Town website.

Question: Clarification of \$6000.00 charge from the Canadian National Railroad per railroad information and requirements section letter dated June 2, 2011. Is the fee to be paid by the owner (town of Waterford) or the contractor awarded the project?

Response: The \$6,000.00 fee to CN Railroad has been paid by the Town. The Contractor is not responsible for this fee.