

**Town of Waterford
Board of
Selectmen and Utility Commission
Harrisons' Landing Sewers and Roadway Improvements
And
Maple Court Water & Sewer Extension
Bid #12-102
RESPONSE TO QUESTIONS
November 16, 2011**

Question:

I respectfully request Cummins be added as an acceptable manufacturer for the generator and ATS for this project. Section 2.8 of the bid document indicates the standby power system shall be manufactured by KOHLER POWER SYSTEMS.

Answer:

Cummins may be bid as long as the equipment meets or exceeds the requested specifications.